

Notice Inviting Quotation

NIQ. No: **04/2011-12**

Dated: **20-09-2011.**

Sealed Quotations are hereby invited by the undersigned from the authorised Firm / Agency / Company for Supplying of **Server Computer (HP/IBM)**, **On-Line UPS(Liebert)**, **1.5 ton Split AC(5 star rated)** etc. The list of Articles is enclosed in **Annexure -I**. Please follow the given format. Agency may not quote all the Items rate, so fill **(X)**.

Quotation is to be submitted to the *Executive Officer, Alipurduar-II Panchayat Samiti, Jasodanga, Jalpaiguri*, within **12.10.2011 upto 04:00pm.**

Intending Agencies should submit following **Xerox** with the valid Quotation:-

1. **Sales Tax Clearance Certificate (VAT)**
2. **Trade License**
3. **Professional Tax Clearance Certificate**
4. **PAN Card.**
5. **Credential for doing the similar type of Job not less than Rs.3 (Three) Lakhs. (Work-order should not be treated as Credential)**
6. **Firm/Agency must have accountability Statement with the Manufacturer**

For more details log on to ::
www.wbprd.gov.in

Note: Every Agency should mention a running Phone Number (Mobile) related Contact Name with the Quotation.

Successful quotationer should have to deposit 5% of the quoted amount as Security for one year in the form of DCR/KVP/NSC/DD etc. favouring The Executive Officer, Alipurduar-II P.S.

Executive Officer,
Alipurduar-II Panchayat Samiti

ALIPURDUAR NO - II PANCHAYAT SAMITI.
PO: JASODANGA, DIST: JALPAIGURI, WEST BENGAL.
PHONE: 03564-224203 / 224202. E-mail: bdo.apd2@gmail.com

Memo No...387(12)

Date...20.09.2011

Copy forwarded for information to:-

1. The District Magistrate, Jalpaiguri.
2. The State Co-ordinator, Women Development, P&RD Department, Kolkata with a request to publish in the department website.
3. The Additional Executive Officer, Jalpaiguri Zilla Parishad. with a request to publish in the Zilla Parishad's website.
4. The Sub-Divisional Officer, Alipurduar.
5. The Sabhapati, Alipurduar-II Panchayat Samiti.
6. The Sub-Divisional Information Officer, Alipurduar.
7. The Sub-Post Master, Alipurduar.
8. The Sub-Post Master, Alipurduar Court.
9. Head Clerk, Alipurduar-II Block.
10. Accounts Clerk, Alipurduar - II P.S.
11. Tathyा Mitra Kendra, Jasodanga.
12. Office Notice Board.

Executive Officer,
Alipurduar-II Panchayat Samiti

ANNEXURE - I

1. **Air Conditioning Machine (SPLIT – 1.5 Ton)(5 star rated) : 1 No.**
(Sumsang / Hitachi / Blue Star / Carrier) (Specification Attached in different sheet)
2. **Server Computer (HP / IBM) : 1 No.**
(Specification Attached in different sheet)
3. **6-KVA ONLINE UPS (EMERSON-LIEBERT/APC) : 1 No.**
(with 4Hr. Full load Back-up Facility) (Specification Attached in different sheet)
4. **6U Rack (for Data Sharer Switch) : 1 No.**
5. **8 port 10/100/1000GBPS Data Sharer Switch (Dlink) : 1 No.**
6. **CAT – 6 Patch Cord : 20 Nos.**
7. **I.O. Switch/Boxes : 10 Nos.**
8. **Microsoft Server 2003 (with Media Pack) : 1 No.**

Executive Officer
Alipurduar-II Panchayat Samiti

TECHNICAL SPECIFICATIONS FOR 6 KVA UPS SYSTEM

Sl No	Parameters	Tender Requirements	Vendor's Specifications (please specify)
1	Make	Emerson	
2	Model Name	Power Bank 6000	
3	Type	Online Double Conversion Type. Power components like IGBTs and Capacitors should not be mounted on the same Printed Circuit Board.	
4	Capacity	6 KVA/ 4.2 KW	
5	TECHNOLOGY		
5.1	Principle of operation	Online double conversion	
5.2	Inverter Technology	PWM, Dual IGBT based	
5.3	Make of Power Devices in Inverter	Mitsubishi/ Siemens or similar make	
5.4	No. of Power Devices in Inverter	4 in 2 twin packs	
6	INPUT RATINGS		
6.1	Normal Input Voltage	Single Phase 230 V	
6.2	Permissible Input Voltage Variation	165 V – 265 V	
6.3	Normal Input Frequency	50 HZ	
6.4	Permissible Input frequency Variation	45 Hz to 55 Hz	
6.5	Maximum Input Current without batteries	39 Amps	
6.6	Maximum Input Power without batteries	7600 VA	
6.7	Maximum Input Power without batteries	5134 Watts	
6.8	Input Voltage for which mains and battery share the load for 100% load (SMPS type)	140 V – 165 V	
6.9	Input voltage for which battery backup takes over for 100% load (SMPS type)	140 V	
7	INTERMEDIATE DC CIRCUIT		
7.1	No. of batteries to be connected in one string	16 Nos.	
7.2	Nominal DC Bus Voltage	192 V	
7.3	Normal Battery Voltage	216 V	
7.4	Maximum Charging Current	7.5 Amps	
7.5	Maximum Recharge time to 100% capacity	12 hours	
8	BATTERY DETAILS		
8.1	Battery Type	Sealed Maintenance Free Valve Regulated Lead Acid	
8.2	Battery Make	Global & Yuasa (Rocket) / Panasonic / Amararaja (Quanta) or equivalent	
8.6	Total Battery VAH required	Minimum 24960 VAH for 4hrs battery backup at full load.	
9	OUTPUT RATINGS		
9.1	Output Power at 0.7 power factor	6 KVA	
9.2	Output Power at unity Power Factor	4.2 KVA	
9.3	Nominal Output Voltage	230 V	
9.4	Output Voltage Variation	230 V \pm 1%	
9.5	Output Voltage Distortion at 100% linear load	< 5%	
9.6	Output Voltage Distortion at 100% non linear load	< 3%	
9.7	Crest Factor	3:1	
9.8	Nominal Output Frequency	50 Hz	
9.9	Free Run Frequency Tolerance	\pm 0.5 HZ	
9.10	Output Frequency Tolerance Phase Locked with Mains	\pm 2.5%	

Part No	Product Description	Unit	Price
QL487A	HP ProLiant ML330 G6 / Hot-Plug LFF Model / Intel® Xeon® 2.26GHz/4-core/4MB/80W / 4 GB (2 x 2 GB) PC3-10600R Registered DIMMs /SA P400/256MB BBWC / Embedded NC326i PCI Express Dual Port Gigabit Server Adapter / 1 X 750W Power Supply with RPS enablement kit preinstalled / SATA DVD ROM Drive / 3-3-3 24X7 warranty	1	
516814-B21	HP 300GB 6G SAS 15K 3.5in Dp ENT HDD	3	
503296-B21	HP 460W CS Gold Ht Plg Pwr Supply Kit	1	